

# 自願性產品驗證證書

Certificate of the Voluntary Product Certification

證書號碼： V547056760022號00

Certificate No.

茲據 台芝電氣股份有限公司 申請自願性產品驗證，  
審查結果符合規定，准予登錄並依規定使用登錄之主型式  
及系列型式產品驗證標誌與識別號碼：  
其登載事項如下：



The application made by 台芝電氣股份有限公司 for Voluntary Product Certification has been reviewed and found to be in compliance with related regulations.

V54676-BSMI

Therefore, registration is granted with the Certification Mark and the Identification No. V54676 for all registered products. Details of the registration are as follows :

申請人： 台芝電氣股份有限公司  
Applicant

地址： 臺中市南屯區工業23路7號  
Address

生產廠場： 台芝電氣股份有限公司  
Factory

廠址： 台中市南屯區工業23號7號  
Factory address

產品種類名稱： 大容量無熔線斷路器(限檢驗交流電壓600V以下，額定電流超過800A或短路容量超過220V/50kA、380V/30kA、440V/25kA及600V/20kA)  
Type/name of product

中文名稱： 無熔線斷路器  
Chinese name

英文名稱： MOLDED-CASE CIRCUIT BREAKER  
English name

型式： NF800-UM 3P Ui440V 60Hz 800AF In=700/800A, Ics=63kA at 220V, 43kA at 380V, 33kA at 440V Icu=125kA at 220V, 85kA at 380V, 65kA at 440V  
Type

系列產品： 空白  
Series of type

驗證標準： CNS14816-2 (93年版)  
Standards

發證機關(構)： 經濟部標準檢驗局

Certification Body: This certificate shall be issued by the Certification Body.

核可日期：中華民國	<u>107</u>	年	<u>08</u>	月	<u>13</u>	日
Registration date	2018	(year)	08	(month)	13	(day)
本證書有效期限至	<u>110</u>	年	<u>08</u>	月	<u>12</u>	日
Expiration Date	2021	(year)	08	(month)	12	(day)
發證日期：中華民國	<u>107</u>	年	<u>08</u>	月	<u>13</u>	日
Date of issue	2018	(year)	08	(month)	13	(day)

註：次年度自願性產品驗證年費繳納期限為當年11月30日，逾期未繳納者，經限期繳納屆期未繳納，即依自願性產品驗證實施辦法第21條第8款規定廢止產品驗證，並自次年度1月1日起生效。